



## INSTALLATION, OPERATION & MAINTENANCE INSTRUCTIONS

1455 Kleppe Lane ♦ Sparks, NV 89431-6467 ♦ (775) 359-4712 ♦ Fax (775) 359-7424  
E-mail: [info@hawsco.com](mailto:info@hawsco.com) ♦ website: [www.hawsco.com](http://www.hawsco.com)

No. 0510000770(2)

# Model 9084 Cleansing Stick, 2000 Liter (528 gallon)

### TO ORDER A REPLACEMENT CLEANSING STICK:

Contact your nearest Haws Representative or call Haws Customer Service at  
1-888-640-4297 (toll free), Sparks, Nevada.

### Definition

Model 9084 is an immersible Cleansing Stick that gives continual protection against pathogenic bacteria for water storage systems. It balances the PH of the water preventing the build-up of bio-film, scale, and corrosion for up to 3 years with proper usage.

### Installation Instructions

The unit should be fully immersed in the water to be treated, together with additional units as needed to treat the volume of water present.

The unit(s) may be placed on the bottom of the tank, or leaned against the tank corner if required, and the nylon cord that is attached to one end of the unit (used for retrieval) may be secured to a position outside the tank that can be reached when the occasion demands.

### Maintenance




Depending on the amount of sediment generally experienced with the particular water supply to the tank, the unit should be inspected on at least a 6-month or annual basis. In the event of a build-up of sediment, the unit should be thoroughly washed in clean water (under pressure where possible).

In some rare conditions, a film may coat the surface of the media. This may have a slight effect on performance and the media should therefore be immersed in acetic acid (vinegar is a common format) for a minimum of 30 minutes to remove the film. After rinsing with water, the unit can then be returned to the tank.

When installed correctly the Model 9084 cleansing stick will provide the protection required. However, Haws advises that all systems be regularly monitored, for which purpose ATP (adenosine triphosphate) testing is recommended to enable accurate and rapid in-house monitoring.

NOTES:

1. DIMENSIONS MAY VARY BY ±1/2" [12.7mm].
2. WHEN INSTALLING THIS UNIT, LOCAL , STATE, OR FEDERAL CODES SHOULD BE ADHERED.
3. FAILURE TO FOLLOW INSTALLATION REQUIREMENTS MAY VOID WARRANTY.
4. APPROXIMATE WEIGHT: 7 LBS



		<b>Haws</b> <sup>®</sup>		1455 KLEPPE LANE SPARKS, NEVADA 89431 (775) 359-4712 FAX (775) 359-7424 E-MAIL: HAWS@HAWS.CO.COM WEBSITE: WWW.HAWS.CO.COM	
				ECN NO. H0201 DRAWN: CF APPROVED: FV	REVISED PER: J.P. ECN: 5263 DATE: 12/27/17 DATE: 01/18/18
SCALE: N/A		DRAWING TYPE: INSTALLATION		SIZE: A SHEET 1 OF 1	