


NOTES:

1. WHEN INSTALLING THIS UNIT, LOCAL CODES SHOULD BE ADHERED TO FOR INSTALLATION DIMENSIONS (LOCATIONS), WASTE AND SUPPLY REQUIREMENTS OTHER THAN SHOWN
2. UNIT SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURERS INSTRUCTIONS AND ACCEPTABLE PLUMBING PRACTICES.
3. UNIT SHALL BE INSTALLED SO THE EYEFACE WASH AND SHOWER HEAD DISTANCE ABOVE THE SURFACE ON WHICH THE USER STANDS, AND DISTANCE FROM ANY OBSTRUCTION MEETS THE REQUIREMENT OF THE APPLIED STANDARD (ANSI Z368.1 OR EN 15154-1/2/5 AS APPLICABLE).
4. IF NECESSARY USE LOCTITE 567 SEALANT ON MALE THREADS, JUST ABOVE THE FIRST THREAD.
5. DIMENSIONS MAY VARY BY ± 1/2 INCH [13mm].
6. DIMENSIONS IN BRACKETS, IN DRAWING SPACE, ARE METRIC [mm]



Haws
Since 1906

HAWS AG
BACHMIG 3
3400 BURGGRABEN SWITZERLAND
T +41 (0)34 420 60 00 F +41 (0)34 420 60 01
E-MAIL: INFO@HAWS.CH
WEBSITE: WWW.HAWS.CH

ECN: 0004	REV. ECN: 0004	BY: DATE: 1/23	CHK'D: DATE: 1/23	MODEL(S): 8330 AXION (10004884)	PART NUMBER: 02080174.D
DRAWN: 1/23				SCALE: 1:20	INSTALLATION: SIZE: A
APPROVED: 1/23				DRAWING TYPE: 1	SHEET 1 OF 1